


SMOKE DETECTOR PLAN

- NOTES:**
1. FOR GENERAL NOTES, LEGEND, RISERS, SEE DRAWING F-1-2-1.
  2. ALL ADDRESSABLE SMOKE DETECTOR CIRCUITS SHALL BE RUN TO EXISTING ATC CABINET.
  3. THE CONTRACTOR SHALL DISCONNECT AND REMOVE THE OLD (EXISTING) SMOKE DETECTORS SHOWN TO BE REMOVED ONLY AFTER THE INSTALLED DEVICES ARE OPERATIONAL AS DIRECTED AND IN THE PRESENCE OF THE ENGINEER.
  4. REFER TO THE MECHANICAL DRAWING M-1 FOR THE REQUIREMENTS AND THE LOCATIONS OF THE PLENUM SMOKE DETECTORS.
  5. CONTRACTOR SHALL LOCATE ALL SMOKE DETECTORS PER BUILDING CODE.

Sheet \_\_\_\_\_ of \_\_\_\_\_

**THE PORT AUTHORITY OF NY & NJ**



**Joseph R. Loring & Associates, Inc.**  
consulting engineers

One Pennsylvania Plaza  
New York, New York 10119-0045  
Tel (212) 563-7400  
Fax (212) 563-7382

**SCR Design Organization, Inc.**  
architects  
305 EAST 46 STREET  
NEW YORK, N.Y. 10017  
TEL: (212) 421-3500

No.	Date	Revision	Approved
1	5/24/98	AS BID	DC

Engineering Department  
Design Division

**The World Trade Center**

Title  
**TOWER 2  
FLOOR 44  
FIRE ALARM  
SMOKE DETECTOR  
INSTALLATION AND  
REMOVAL PLAN**

This drawing subject to conditions in contract. All inventions, ideas, designs and methods herein are reserved to Port Authority and may not be used without its written consent.

F.D.	F.D.	4565.000
Designed by	Drawn by	JRLA JOB No.
4/27/98	P.E.N.	3/32"=1'-0"
Date	Checked by	Scale

Contract Number  
WTC-857.090

Drawing Number  
**F-2-44-2**

